REVIEW ARTICLE

Annals of Agricultural and Environmental Medicine 2026, Vol 33, No 3, 305–312
www.aaem.pl

Microbial hazards in rainwater harvesting systems: bacterial sources, indicators, and health implications – a review

Konrad Jamka[1,2,A-D] ✉, Grzegorz Raszewski[2,A,E-F], Grzegorz Łagód[1,A,E-F]

[1] *Department of Water Supply and Wastewater Disposal, Faculty of Environmental Engineering and Energy, University of Technology, Lublin, Poland*
[2] *Toxicology and Food Safety, Institute of Rural Health, Lublin, Poland*
A – Research concept and design, B – Collection and/or assembly of data, C – Data analysis and interpretation, D – Writing the article, E – Critical revision of the article, F – Final approval of the article

Jamka K, Raszewski G, Łagód G. Microbial hazards in rainwater harvesting systems: bacterial sources, indicators, and health implications – a review. Ann Agric Environ Med. 2026;33(3):305–312. doi:10.26444/aaem/235841

Abstract

Introduction and Objective. Rainwater harvesting systems (RWHS) are an important element of sustainable water management in urbanized areas, by supporting retention and adaptation to climate change. The widespread use of RWHS, however, is limited due to concerns about the microbiological purity of the water. The aim of the review is to illustrate the current state of knowledge regarding microbiological hazards and methods of their assessment in the rainwater of RWHS.
Review Methods. A comprehensive literature search was conducted using Scopus, ScienceDirect, and PubMed databases. Publications from 2000–2026 were analyzed, with special consideration of the studies published after 2015. Key words included: rainwater harvesting, RWHS, microbiological contamination, faecal indicator bacteria, FIB, microbial source tracking, MST, quantitative microbial risk assessment, QMRA.
Brief description of the state of knowledge. RWHS systems are an effective tool for rainwater management and protection of its resources in integrated water resource management systems. However, the fundamental limitation to their broader implementation is mainly microbiological hazards, effectively limiting the use of rainwater for domestic and consumption purposes.
Summary. The review organizes the knowledge on the safety of water from RWHS, considers microbiological hazards, FIB indicator bacteria, markers for identification of sources of microbiological contamination (MST), and QMRA microbiological risk assessment methods. It also discusses the limitations associated with FIB, the significance of MST, and the role of QMRA. Current data indicate that untreated water from RWHS is often suitable for use in non-consumption activities; however, it usually exceeds the standards set for drinking water. The water from RWHS intended for drinking most often requires treatment and continuous monitoring.

Key words

public health, microbiological contamination, RWHS – rainwater harvesting system, FIB – faecal indicator bacteria, QMRA – quantitative microbiological risk assessment, MST – microbial source tracking

INTRODUCTION

Water resource management is a key process in water protection, ensuring the sustainable use of these resources in accordance with societal needs. However, it must also consider the protection of ecosystems and biodiversity, account for the impact of climate change, and incorporate water quality monitoring and control to ensure safety for people and the environment [1, 2]. In this context, alongside the monitoring of commonly occurring pollutants, attention should be paid to the health risks associated with micropollutants in water sources [3], as this is an important element of public health protection within sustainable water resource management. In the social dimension, this also encompasses ecological education, actions to protect water and reduce risks associated with extreme hydrometeorological phenomena and pollution, as well as the implementation of appropriate water use regulations [4].

✉ Address for correspondence: Konrad Jamka, Department of Water Supply and Wastewater Disposal, Faculty of Environmental Engineering and Energy, University of Technology, Nadbystrzycka 40B, 20-618 Lublin, Poland
E-mail: jamka.konrad@imw.lublin.pl

Received: 20.07.2026; accepted: 30.08.2026; first published: 15.09.2026

There are various known models of rainwater management that align with the principles of best management practices (BMP), green infrastructure (GI), and low-impact development (LID) solutions [2, 5–9]. Recently, urban areas have seen a rapid development of smart systems for rainwater management and wastewater treatment [10, 11]. An example is the 'sponge city' concept developed in China, which posits that urban systems can and should absorb, retain, purify, and reuse rainwater [10]. This approach, based on LID solutions, has been implemented in numerous pilot projects [12, 13]. These systems, which integrate water infiltration, storage, retention, and drainage processes, enable the utilization of up to 80% of precipitation while simultaneously providing numerous ecological benefits [14].

Environmental and economic benefits of RWHS. Rainwater harvesting systems (RWHS), which encompass the collection of runoff from roofs and impermeable surfaces, its storage, and subsequent use, constitute an essential element of modern water resource management [15]. According to Ghaffarian et al. [16], the widespread implementation of RWHS in urban areas could satisfy up to 80–90% of household water demand. RWHS are of particular importance in countries with limited

water resources, where water deficits force the substitution of potable water with rainwater for non-consumptive applications [17]. The use of relatively clean rainwater for applications that do not require drinking-water quality helps to mitigate severe water shortages and reduce the volume of stormwater runoff in municipal drainage systems [18, 19].

The implementation of RWHS brings numerous economic benefits, mainly by increasing water availability and lowering the costs of water supply and consumption, especially in countries with limited resources [20, 21]. Furthermore, RWHS contribute to energy savings, reduced CO_2 emissions [22], stormwater runoff control [23], decreased pollutant loads, and improved groundwater quality owing to natural filtration processes [18].

Additionally, in rural areas, where water is used for both domestic and agricultural purposes (such as farming and animal husbandry), RWHS must exhibit high water-collection efficiency, which remains a significant challenge [24].

Integrating RWHS with stormwater management strategies – including rainwater treatment and monitoring, as well as green infrastructure and bioretention systems – can further benefit ecosystems, enhance biodiversity, improve water use efficiency, and support better living conditions for humans and animals, in alignment with sustainable development goals [2, 18].

RWHS functioning, limitations, and uncertainties. The functioning of RWHS is strongly dependent on climatic conditions, primarily the amount and intensity of precipitation, the size and type of the catchment area, the level and type of water demand, and other extensively studied factors that impact technical and economic optimization in stormwater management [25–27]. Accounting for these conditions is crucial, as the incorrect estimation or omission of these factors can significantly distort the assessment of the environmental and economic benefits resulting from RWHS implementation [27–29].

RWHS also exhibit other important limitations [30], resulting from the high variability of hydrological conditions, difficulties in real-time system optimization, and a limited capacity to adapt to changes in water demand. This necessitates the design, development, and implementation of smart technologies – such as predictive models, sensors, and control and optimization algorithms – to improve RWHS performance [31]. These advancements will ensure that households receive water of appropriate quantity and quality, enabling a more stable, safe, and efficient use of rainwater [30, 31].

However, a primary limitation of RWHS is the widespread perception that, due to the risks of microbiological and chemical contamination alongside insufficient rainwater monitoring and quality control [32], these systems cannot be recognized as a potential source of potable water [15, 31, 33]. Consequently, the successful implementation of RWHS largely depends on public attitudes and the social acceptance of this technology [34]. Key influencing factors include the real and perceived costs of rainwater harvesting [35], water quality concerns [36], a lack of reliable knowledge about RWHS [34, 36], and apprehensions regarding unfavourable regulations and maintenance costs [35]. Incentives, support programmes, and favourable regulations also play a vital role in promoting RWHS implementation [37]. Nevertheless, recent research on social attitudes [38] indicates that despite initial concerns, many users become advocates for rainwater harvesting and its economical utilization once the systems are installed.

Environmental and structural determinants of microbiological water quality in RWHS. In RWHS, the microbiological quality of water results from complex interactions between environmental and structural factors. These include the properties of the catchment surface, local sources of contamination, rainfall characteristics, and various physicochemical and biological processes occurring within the storage tanks [39]. These factors determine the significant qualitative and quantitative variability of the microbiome across different systems. The type of roofing material dictates the specifics of retention and subsequent wash-off of microorganisms by surface runoff. It has been shown that water running off metal roofs generally features lower concentrations of microorganisms, including pathogens, compared to other types of roof coverings [40]. However, it should be noted that the ultimate impact of the roof type on microbiological safety is closely linked to many additional variables.

Atmospheric deposition constitutes another significant source of contamination – not only chemical but also microbiological. Dust, aerosols, and organic matter originating from the atmosphere accumulate on roof surfaces, serving as a specific carrier for microorganisms [39]. Rainfall washes off the material previously deposited on the roof while simultaneously scavenging airborne contaminants and transporting them to the RWHS. The intensity and extent of this process is primarily influenced by the length of the antecedent dry period and current meteorological conditions. Furthermore, one of the primary sources of pathogens introduced into RWHS is animal faecal contamination. This primarily involves bacteria such as *Campylobacter* spp., *Salmonella* spp., and pathogenic strains of *Escherichia coli*, which are washed from roof surfaces and lead to a drastic increase in their concentration in the harvested water. The scale of this phenomenon depends mainly on the frequency and duration of animal (e.g., bird) presence on roofs, the time of faeces accumulation during dry periods, and the intensity of the initial runoff phase [41].

During water storage, microorganisms associated with organic and inorganic matter undergo sedimentation and accumulate at the bottom of the tank. This leads to the formation of a secondary reservoir of potential pathogens – including opportunistic bacteria such as *Pseudomonas aeruginosa* and *Legionella* spp. – which can be re-released into the water column as a result of mechanical or hydraulic disturbances. Additionally, a biofilm forms on the internal surfaces of the installation and tank walls. Studies indicate that the tank's construction material is of key importance for the composition of the microbiome, both in the water and within the biofilm structure itself [42]. Mitigating the load of these contaminants involves accounting for the so-called first-flush effect. The initial portion of water running off after a dry period carries a significantly elevated load of microbiological contaminants, after which its quality improves rapidly. This phenomenon dictates the design requirements of RWHS, which should be equipped with first-flush diverters to minimize the load on the main storage tank. As demonstrated, the intensity of this effect depends primarily on the characteristics of the rainfall itself, the

length of the preceding dry period, as well as the type and technical condition of the roof covering [43].

Microbiological risks associated with RWHS and their significance for public health. Alongside chemical pollutants, a key factor determining the suitability of rainwater for domestic applications is microbiological risk, which poses a significant threat to human health [36, 44]. Because the microbiological quality of water in RWHS varies due to diverse contamination sources, unambiguously determining its safe applications can be challenging [45]. Identifying contaminants and their sources is essential to ensure the safe utilization of rainwater and to develop effective treatment strategies [36, 37]. This approach aligns with the principles of sustainable water management, which aims to minimize exposure to human pathogens [36, 46].

While the comprehensive monitoring of all human pathogens is the optimal solution, their high diversity and variability in RWHS make this approach costly, analytically complex, and impractical for routine application [47]. Therefore, faecal indicator bacteria (FIB) and genetic markers for microbial source tracking (MST) are commonly used to support pathogen detection and contamination source identification, thereby aiding health risk assessment in RWHS [48, 49].

A common approach for assessing the microbiological quality of water is the simultaneous analysis of multiple FIB groups alongside selected pathogens in rainwater [50]. Although this approach provides a comprehensive characterization of contaminants, its diagnostic value remains limited [51]. This limitation stems from the lack of a clear correlation between the presence of FIB and the occurrence of human pathogens, which undermines the reliability of traditional indicators in RWHS risk assessment [52].

To address these limitations, bacteria of the genus *Bacteroides* spp. have been proposed as an alternative indicator of faecal contamination due to their significant abundance in the human gut microbiota and high host specificity [53]. Of particular importance is the HF183 marker, which is specific to human faecal contamination and commonly found in RWHS [54].

Recent research indicates that, compared to conventional FIB, MST markers like HF183 enable the precise identification of contamination sources and improve the reliability of health risk assessments [55]. This approach reflects current trends of integrating molecular methods (e.g., qPCR, eDNA) into the environmental monitoring of water systems [56].

Despite their limitations, FIB remain an important element of RWHS microbiological monitoring, especially for assessing seasonal variability, treatment effectiveness, maintenance planning, and system design [45]. Consequently, integrating traditional FIB with MST tools currently constitutes the most comprehensive and recommended approach for assessing microbiological safety in RWHS [57].

Faecal indicator bacteria as a tool for assessing water quality in RWHS. Commonly used faecal indicator bacteria (FIB) include coliform bacteria (total coliforms – TC), *Escherichia coli* (*E. coli*), enterococci, and *Clostridium perfringens* (*C. perfringens*). These microorganisms are utilized to assess the microbiological quality of environmental waters, including rainwater harvested in RWHS, as well as to indirectly assess the risk of enteric pathogens [55].

Coliform bacteria include four genera belonging to the family *Enterobacteriaceae*: *Escherichia*, *Enterobacter, Klebsiella*, and *Citrobacter*, which typically constitute less than 1% of the healthy human gut microbiota. Modern metagenomic profiling reveals that *Enterobacteriaceae* are a minor fraction – for example, *E. coli* reaches an abundance of 0.1% or greater in only 15% of healthy stool microbiomes, while the gastrointestinal community is primarily dominated by the *Firmicutes* and *Bacteroidetes phyla* [58]. This group and the total microbial count are utilized as indicators for assessing microbiological purity and the integrity of water distribution systems [59]. Currently, it is widely recognized that the presence of total coliforms (TC) does not always unambiguously indicate fresh faecal contamination. This is because a portion of the microorganisms classified in this group can naturally reside and multiply in environments free from faecal contamination [55]. Therefore, a more effective and frequently used indicator of faecal contamination is *E. coli* of faecal origin, which accounts for over 95% of the faecal coliforms isolated from water. For monitoring purposes, the target is typically thermotolerant *E. coli* originating from the intestines of warm-blooded animals, capable of lactose fermentation at 44.5–45.5 °C [55].

Identifying the origin of rainwater contamination is of particular importance, as human-derived contamination carries a higher risk of containing human-specific pathogens [60]. The majority of *E. coli* strains present in human faeces are not host-specific, which significantly limits the precise determination of the source of faecal contamination. However, certain strains – such as phylogroup B2 (subgroup VIII, serotype O81), isolated mainly from humans, and phylogroup B1 carrying the hly virulence gene, more often associated with animals – have been described. These strains are considered potential markers for identifying faecal contamination sources in MST studies; however, their environmental application remains limited due to the high genetic variability of *E. coli* [61].

The concentration of *E. coli* in rainwater remains strongly dependent on environmental factors, particularly climate change, air temperature, and the intensity and frequency of precipitation. These factors influence both bacterial survival in the environment and the surface runoff processes responsible for transporting faecal contaminants into RWHS [62].

Similar dependencies are observed with enterococci, which – alongside *E. coli* – constitute a commonly used indicator of microbiological water contamination. In contrast to *E. coli*, they exhibit higher resistance to adverse environmental conditions and can occur independently of fresh faecal contamination [55]. Enterococci are widely recognized as a significant indicator for identifying faecal contamination and, indirectly, for assessing the potential presence of enteric pathogens, especially in rainwater quality analyses and sanitary risk assessments. Two species dominate the population of human faecal enterococci: *Enterococcus faecium* and *Enterococcus faecalis* [63]. These bacteria naturally colonize the large intestines of humans and the gastrointestinal tracts of other warm-blooded animals, reaching high concentrations in excreted feces.

In accordance with the guidelines of the World Health Organization [64] and the regulations in force in many countries, including Poland, concerning the quality of water intended for human consumption, *E. coli*, coliform bacteria, and enterococci must be absent in a 100 mL sample of drinking water [50].

Clostridium perfringens was one of the first bacterial species recognized as an indicator of faecal contamination in the aquatic environment [65]. This bacterium usually occurs in higher concentrations in human faeces than in animal faeces, although its presence is not limited solely to intestinal sources. *C. perfringens* has been isolated from the gastrointestinal tracts of fish, pigs, and ducks, as well as from soil and marine sediments [60]. Due to its ability to form highly resistant spores and survive for long periods in the aquatic environment, it is recognized as a useful indicator of long-term and cumulative faecal contamination [66]. The dissemination of *C. perfringens* spores in the environment, its limited host specificity, and the weak correlation of its abundance with other FIB render its usefulness as an independent microbiological indicator debatable. However, it has been shown that using *C. perfringens* alongside other FIB increases the effectiveness of predicting the presence of pathogens in the aquatic environment, including within RWHS [55].

Microbial source tracking markers and pathogens in RWHS as indicators of health threats. Contemporary research indicates a limited correlation between the presence of FIB and the occurrence of other pathogens in RWHS, which undermines the usefulness of these traditional faecal indicators as the sole tool for microbiological risk assessment [52]. Consequently, increasing attention is being paid to microbial source tracking (MST) markers, which enable the identification of contamination sources and provide a more accurate assessment of health threats. This information is crucial for assessing the potential for the safe utilization of harvested rainwater and, if necessary, for developing appropriate treatment strategies [45].

The genus Bacteroides has been proposed as an MST marker and an alternative to conventional FIB in evaluating faecal contamination during water quality studies [67]. Bacteria of *Bacteroides* spp. are a dominant component of the gut microbiota of humans and other warm-blooded animals, constituting approximately 30–50% of faecal bacteria. Their high host specificity makes them particularly valuable indicators for monitoring the microbiological quality of water in RWHS [65, 67]. In water samples, host-associated 16S rDNA target genes can be utilized to detect and quantify *Bacteroides* spp., serving as MST markers for identifying and tracking faecal contamination originating from humans and animals [68].

Numerous *Bacteroides*-based MST markers have been described, including HF183, HF134, BacHum-UCD, HuBac, and Human-Bac1 [68]. Among them, HF183 is the most thoroughly investigated and widely used marker for detecting human faecal contamination due to its high sensitivity and specificity, as well as its ability to distinguish human-derived contamination from that of animal origin [68]. The occurrence of the HF183 marker has been frequently reported in RWHS gutters and storage tanks [48, 54].

Apart from *Bacteroides*-associated markers, several other MST markers have been utilized to detect human faecal contamination in surface and groundwater, including harvested rainwater. These include CPQ_064, crAssphage CPQ_056, human polyomaviruses (HPyV), pepper mild mottle virus (PMMoV), and Lachno3 [69]. However, the quantitative determination of viral markers in harvested rainwater remains challenging due to methodological and environmental limitations that influence their detection and persistence in water matrices [70]. The detection frequencies and concentrations of FIB and MST markers reported in RWHS worldwide are summarized in Tables 1 and 2.

Table 1. Occurrence of faecal indicator bacteria (FIB) in rainwater harvesting systems

Microorganisms	Methods	Positive samples n (%)	Concentration (CFU/100 mL)	Year (Reference) Country
E. coli	C-BM; IDEXX	9 (64)	<1 – 20	[71] USA
Total coliforms		14 (100)	43 –> 2420	
E. coli	MF; C-BM	38 (57)	0 – 9200	[72] Australia
Enterococcus spp.		55 (82)	0 – 32000	
C. perfringens		33 (49)	0 – 120	
E. coli	MF; C-BM	NM	up to 50	[73] Poland
Enterococcus spp.			up to 77	
C. perfringens			detected only in spring	
Total bacteria			7×10^5 in summer, 3.5×10^5 in spring	
Clostridium perfringens	C-BM	17 (81)	4 –> 300	[74] Czech Republic
E. coli	C-BM; IDEXX	70 (11.9)	33.2 (mean)	[75] USA
Total coliforms		381 (64.9)	480.4 (mean)	

Table 2. Occurrence of microbial source tracking markers (MST) in rainwater harvesting systems

Microorganisms / Marker	Methods	Positive samples n (%)	Concentration (gene copies /100 mL)	Year (Reference) Country
HF183 marker	qPCR	60 (100)	1.54×10^2 – 6.59×10^4	[54] South Africa
HF183 marker	qPCR	25 (76)	0 – 44	[48] South Africa

In these studies, individual FIB were most frequently quantified using membrane filtration and culture-based methods, which were occasionally supplemented with molecular qPCR analysis. The qPCR method enables the detection of both viable and non-culturable microorganisms, which often results in higher recorded concentrations [45].

Published data indicate significant variability in the microbiological quality of harvested rainwater in RWHS. The primary factors recognized as influencing the variability of FIB concentrations include: (1) meteorological conditions (especially wind direction and speed), (2) the location and time of sampling, (3) the type of catchment area and roof materials, as well as the construction of storage tanks, (4) the presence of animals, and (5) the applied laboratory methods [40, 52].

The most frequently detected FIB were coliform bacteria, *Escherichia coli*, and *Enterococcus* spp., where positive detection rates generally exceeded 60%, and concentrations often exceeded the World Health Organization (WHO) guidelines for drinking water quality (Tab. 1). Only a limited number of samples collected from RWHS tanks, including those studied in Singapore and Australia, yielded negative results for *E. coli* or *Enterococcus* spp. [76, 77]. *Clostridium perfringens*, considered an indicator of the persistence of faecal contamination in the environment,

was detected in 49–91% of samples at concentrations reaching 300 CFU/100 mL [74].

While the MST marker HF183 is frequently utilized to identify anthropogenic sources of faecal contamination in environmental waters, there is currently a significant data gap regarding its quantitative occurrence and detection frequency specifically within RWHS. The limited available data (Tab. 2), originating predominantly from a single research group, confirm its presence in RWH systems but do not provide a sufficient basis to establish a generalized detection frequency. This highlights the need for further targeted research in this area.

Investigations into the associations between MST markers (mainly HF183) and FIB (mainly *E. coli* and *Enterococcus* spp.) have yielded inconclusive results [56] demonstrating both positive and negative correlations. Similar inconsistencies were observed when investigating their relationships with various other pathogens [48, 54]. These results suggest that while MST markers are useful for indicating contamination sources, they may not reflect all associated health threats – such as those posed by pathogens present in animal faeces [78].

Therefore, there is a need for the direct monitoring of opportunistic and pathogenic microorganisms in RWHS. Molecular studies of rainwater most frequently indicate the presence of *Campylobacter*, *Salmonella*, *Legionella*, *Pseudomonas*, *Cryptosporidium*, and *Giardia*. Additionally, dangerous pathogenic genera, such as *Mycobacterium* (e.g., *Mycobacterium tuberculosis*), *Yersinia* spp., and *Listeria* (*Listeria monocytogenes*), have been found [45]. Cross-sectional Australian studies on RWHS primarily identified microorganisms such as *E. coli*, total and fecal coliforms, *Campylobacter*, *Salmonella*, *Legionella*, *Pseudomonas*, *Cryptosporidium*, enterococci, *Giardia*, *Aeromonas*, and the *Mycobacterium avium* complex (MAC) [76]. The latest reviews of microbiological contaminants in RWHS [79] confirmed the occurrence mainly of *E. coli*, *Salmonella* spp., *Campylobacter* spp., and *Legionella*. These reviews also highlight the main sources of contamination (e.g., urban bird droppings), their regional differentiation, and the widespread presence of antibiotic-resistant strains (e.g., to ampicillin, ciprofloxacin, and tetracycline), which constitutes an additional threat to public health in urban RWHS.

Quantitative microbial risk assessment (QMRA) of rainwater in RWHS. Identifying detected pathogens and their contamination sources is essential for developing appropriate strategies to prevent contamination and assessing the human health risks associated with RWHS water utilization. Quantitative Microbial Risk Assessment (QMRA) is a tool used to estimate the probability of adverse health effects resulting from human exposure to pathogenic microorganisms in water, including in RWHS. QMRA enables the assessment of the microbiological safety of RWHS water used for various purposes (e.g., irrigation, toilet flushing, hygiene activities), as well as the evaluation of greywater or drinking water post-treatment. It also allows for the assessment of potential pathogen exposure risks and the comparison of various RWHS management scenarios, such as different utilization methods, water treatment technologies, consumer behaviours, or regulatory policies [48,80].

Risk modelling within the QMRA framework consists of four main stages: (1) hazard identification, (2) exposure assessment, (3) dose-response modelling, and (4) risk characterization. The aim of the first stage is to determine which pathogens posing a health threat to consumers can occur in rainwater. The second stage, exposure assessment, estimates the pathogen load to which a person may be exposed under a specific rainwater utilization scenario. The third stage analyzes the probability of infection (or illness) based on the ingested dose and pathogen type. Integrating data from all stages allows for the development of a predictive model aimed at estimating the health risk of infection with a specific pathogen based on defined exposure scenarios within a particular environment or activity [81,82]. For example, Ahmed et al. [47] demonstrated that when utilizing rainwater for toilet flushing, the annual risk of *Campylobacter* infection was 3×10^{-4}, which exceeds the permissible infection risk threshold of 10^{-4} pppy set by the WHO [64].

Despite the wide application of QMRA as a tool supporting microbiological water safety planning and decision-making processes, this risk assessment is burdened by the inherent variability of microbiological processes. Additionally, it faces significant uncertainties regarding the estimation of pathogen presence and the underlying modelling assumptions [83].

A relationship between illness and the occurrence of microorganisms in rainwater has been established for numerous pathogens, including *Clostridium botulinum*, *Campylobacter* spp., *Salmonella typhimurium*, *Legionella pneumophila*, *Mycobacterium avium* complex (MAC), *Naegleria* spp., *Salmonella arechevalata*, *Cryptosporidium*, and *Giardia* – which are major etiological agents of gastroenteritis worldwide [45].

Epidemiological studies based on QMRA, published by Hamilton et al. [45], evaluated the associations between RWHS use and gastrointestinal diseases in various contexts. They found no statistically significant differences in the risk of gastrointestinal diseases between individuals consuming RWHS rainwater and those using so-called 'improved water sources'. According to the WHO definition [64], improved water sources are those protected from external contamination, particularly faecal matter. Significantly, the analysis demonstrated a lower health risk associated with rainwater consumption compared to water from unimproved sources. However, it must be noted that these findings may not apply to young children, the elderly, or immunocompromised individuals. Furthermore, drinking rainwater may carry a higher risk of campylobacteriosis compared to alternative sources [45]. Conversely, a study involving a large cohort of children found no increased risk of gastroenteritis among those drinking rainwater compared to those consuming treated tap water [84]. Similar results were reported for diarrheal diseases [85], although another study found that rainwater consumption was strongly associated with diarrheal diseases, accounting for 77% of reported cases [86].

In summary, consuming water from RWHS poses a lower risk of gastrointestinal disease compared to alternative or unimproved water sources. However, assessing the risk of RWHS water utilization relative to improved water sources is highly dependent on source water quality and cannot be generalized as an absolute metric [45]. Table 3 presents exemplary annual microbiological risk values for various applications of treated and untreated RWHS water across several pathogens, as determined using QMRA. According to the WHO [64], the acceptable risk level for drinking

water quality is 10^{-4} infections per person per year (i.e., a maximum of one infection per 10,000 inhabitants annually). These values are subsequently adjusted using the Disability-Adjusted Life Years (DALY) metric, establishing a benchmark of 10^{-6} DALYs per person per year (pppy) [45]. Adopting an annual risk threshold of 10^{-6} DALYs pppy aligns with WHO guidelines [45, 64].

Table 3. Annual risk values for different RWHS uses reported in QMRA studies

Reference pathogen	Water use / Exposure scenario	Annual Infection Risk (pppy) WHO Benchmark: 10^{-4}	Annual DALYs (pppy) WHO Benchmark: 10^{-6}	Reference
Campylobacter ssp.	Drinking	—	3.40×10^{-4}	[87]
	Bathing	—	6.50×10^{-7}	
	Food washing	—	4.00×10^{-7}	
	Hose irrigation	—	2.10×10^{-7}	
	Toilet flushing	—	1.40×10^{-7}	
Salmonella spp.	Drinking	$1.3 \times 10^{-1} – 6.9 \times 10^{-1}$	—	[46]
	Bathing	$2.5 \times 10^{-4} – 1.3 \times 10^{-3}$	—	
	Hose irrigation – aerosol	$7.1 \times 10^{-8} – 4.1 \times 10^{-7}$	—	
	Crops irrigation (cucumber, tomato, lettuce)	$1.39 \times 10^{-4} – 1.62 \times 10^{-3}$	—	[88]
G. lamblia	Drinking	$2.0 \times 10^{-1} – 1.3 \times 10^{0}$	—	[46]
	Bathing	$3.9 \times 10^{-4} – 2.4 \times 10^{-3}$	—	
	Hose irrigation – aerosol	$1.1 \times 10^{-7} – 6.9 \times 10^{-7}$	—	
	Crops irrigation (cucumber, tomato, lettuce)	$5.53 \times 10^{-4} – 5.49 \times 10^{-3}$	—	[88]
Campylobacter jejuni	Bathing in treated rainwater (sand filtration and UV disinfection)	7.9×10^{-8}	—	[89]
Salmonella enterica		7.7×10^{-9}	—	
Cryptosporidium spp.		1.4×10^{-3}	—	
Giardia spp.		4.4×10^{-6}	—	
E. coli O157:H7		1.3×10^{-4}	—	
L. pneumophila		2.7×10^{-7}	—	

The consumption of untreated RWHS water has been associated with risk levels exceeding WHO recommendations. However, studies have shown that applying non-chlorine treatment methods lowers this risk to 2×10^{-6} DALYs pppy, bringing it closer to WHO reference values [87]. For non-potable applications of RWHS water, the infection risk for *Campylobacter* spp. – often used as a reference microorganism in QMRA – remained at approximately 10^{-7}, thus meeting WHO criteria [87, 90].

The risk of infection from *Salmonella* spp., *Giardia lamblia*, and *Legionella pneumophila* during non-consumptive uses of RWHS water also remained low. Conversely, the direct consumption of untreated water containing *Salmonella* spp. or *G. lamblia* poses an unacceptable risk level for drinking water [46].

Fortunately, implementing various RWHS water treatment methods significantly reduced the infection risk for *Campylobacter jejuni*, *Salmonella enterica*, *Legionella pneumophila*, and *Giardia* spp. to well below the reference limit (Tab. 3). The risk only exceeded this acceptable threshold for *Cryptosporidium* spp. and *E. coli* O157:H7 [89].

CONCLUSIONS

Health risks associated with the use of water from RWHS are primarily linked to the direct consumption of untreated water, particularly in the presence of *Salmonella* spp. and *Giardia lamblia*. For non-potable applications, this risk is generally low. Furthermore, when evaluating the risk using *Campylobacter* spp. as a reference bacterium, the estimated risk may even comply with the WHO criteria for non-potable water.

Water treatment processes in RWHS significantly reduce microbiological risks to acceptable levels for a range of pathogens, including *C. jejuni*, *S. enterica*, and *L. pneumophila*. However, *Cryptosporidium* spp. and *E. coli* O157:H7 can still present an unacceptable risk. Consequently, the efficacy of treatment methods should be evaluated strictly in the context of specific pathogens and the intended end-use scenarios.

The weak correlation between traditional faecal indicator bacteria (FIB) and actual pathogens in water, as demonstrated in the literature, necessitates supplementing routine FIB monitoring with assessments based on appropriately selected reference microorganisms within the Quantitative Microbial Risk Assessment (QMRA) framework. Incorporating *Campylobacter* spp. into QMRA models allows for a more accurate estimation of the actual health risks associated with rainwater reuse than relying solely on FIB detection. Unfortunately, the lack of reliable data regarding the variability of *Campylobacter* spp. concentrations in RWHS, combined with insufficient source identification, necessitates the probabilistic modelling of concentration variance rather than the use of point estimates. This data gap limits the overall reliability of QMRA and the accuracy of estimating infection probabilities within the population.

REFERENCES

1. Brown CM, Lund JR, Cai X, et al. The future of water resources systems analysis: Toward a scientific framework for sustainable water management. Water Resour Res. 2015;51:6110–24. https://doi.org/10.1002/2015WR017114
2. Xu J, Dai J, Wu X, et al. Urban rainwater utilization: A review of management modes and harvesting systems. Front Environ Sci. 2023;11:1025665. https://doi.org/10.3389/fenvs.2023.1025665
3. Raszewski G, Jamka K, Bojar H, et al. Endocrine disrupting micropollutants in water and their effects on human fertility and fecundity. Ann Agric Environ Med. 2022;29:477–82. https://doi.org/10.26444/aaem/156694
4. Simonovic S. Systems Approach to Management of Water Resources—Toward Performance Based Water Resources Engineering. Water. 2020;12:1208. https://doi.org/10.3390/w12041208

5. Białek A, Łagód G. The impact of physical-geographical conditions on the sizing of rain gardens: A spatial case of Poland. J Ecol Eng. 2025;26:460–76. https://doi.org/10.12911/22998993/207167
6. Rodak CM, Jayakaran AD, Moore TL, et al. Urban stormwater characterization, control, and treatment. Water Environ Res. 2020;92:1552–86. https://doi.org/10.1002/wer.1403
7. Szeląg B, Kiczko A, Musz-Pomorska A, et al. Advanced Graphical–Analytical Method of Pipe Tank Design Integrated with Sensitivity Analysis for Sustainable Stormwater Management in Urbanized Catchments. Water. 2021;13:1035. https://doi.org/10.3390/w13081035
8. Szeląg B, Łagód G, Musz-Pomorska A, et al. Development of Rainfall-Runoff Models for Sustainable Stormwater Management in Urbanized Catchments. Water. 2022;14:1997. https://doi.org/10.3390/w14131997
9. Widomski MK, Musz-Pomorska A. Hydrologic Efficiency of Rain Gardens as Countermeasures to Overuse of Concrete in Historical Public Spaces. Sustainability 2025;17:2527. https://doi.org/10.3390/su17062527
10. Qi Y, Chan FKS, Thorne C, et al. Addressing Challenges of Urban Water Management in Chinese Sponge Cities via Nature-Based Solutions. Water. 2020;12:2788. https://doi.org/10.3390/w12102788
11. Szeląg B, Drewnowski J, Łagód G, et al. Soft Sensor Application in Identification of the Activated Sludge Bulking Considering the Technological and Economical Aspects of Smart Systems Functioning. Sensors 2020;20:1941. https://doi.org/10.3390/s20071941
12. Eyni A, Skardi MJE, Kerachian R. A regret-based behavioral model for shared water resources management: Application of the correlated equilibrium concept. Sci Total Environ. 2021;759:143892. https://doi.org/10.1016/j.scitotenv.2020.143892
13. Iwanek M, Suchorab P. Profitability Analysis of Selected Low Impact Development Methods for Decentralised Rainwater Management: A Case Study from Lublin Region, Poland. Water. 2023;15:2601. https://doi.org/10.3390/w15142601
14. Sang Y-F, Yang M. Urban waterlogs control in China: more effective strategies and actions are needed. Nat Hazards. 2017;85:1291–4. https://doi.org/10.1007/s11069-016-2614-4
15. Huang Z, Nya EL, Rahman MA, et al. Integrated Water Resource Management: Rethinking the Contribution of Rainwater Harvesting. Sustainability. 2021;13:8338. https://doi.org/10.3390/su13158338
16. GhaffarianHoseini A, Tookey J, GhaffarianHoseini A, et al. State of the art of rainwater harvesting systems towards promoting green built environments: a review. Desalination Water Treat. 2016;57:95–104. https://doi.org/10.1080/19443994.2015.1021097
17. Page D, Gonzalez D, Sidhu J, et al. Assessment of treatment options of recycling urban stormwater recycling via aquifers to produce drinking water quality. Urban Water J. 2016;13:657–62. https://doi.org/10.1080/1573062X.2015.1024691
18. Ali S, Sang Y-F, Yang M, et al. Influences of rainfall characteristics on water saving and stormwater control performances of rainwater harvesting systems. J Environ Manage. 2025;375:124318. https://doi.org/10.1016/j.jenvman.2025.124318
19. Rapacewicz R, Kudlek E, Brukało K. Rainwater and stormwater quality in terms of its potential use in swimming pool installations. Desalination Water Treat. 2025;321:100918. https://doi.org/10.1016/j.dwt.2024.100918
20. Campos Cardoso RN, Cavalcante Blanco CJ, Duarte JM. Technical and financial feasibility of rainwater harvesting systems in public buildings in Amazon, Brazil. J Clean Prod. 2020;260:121054. https://doi.org/10.1016/j.jclepro.2020.121054
21. Severis RM, Silva FAD, Wahrlich J, et al. Economic analysis and risk-based assessment of the financial losses of domestic rainwater harvesting systems. Resour Conserv Recycl. 2019;146:206–17. https://doi.org/10.1016/j.resconrec.2019.03.040
22. Leong JYC, Balan P, Chong MN, et al. Life-cycle assessment and life-cycle cost analysis of decentralised rainwater harvesting, greywater recycling and hybrid rainwater-greywater systems. J Clean Prod. 2019;229:1211–24. https://doi.org/10.1016/j.jclepro.2019.05.046
23. Custódio DA, Ghisi E. Impact of residential rainwater harvesting on stormwater runoff. J Environ Manage. 2023;326:116814. https://doi.org/10.1016/j.jenvman.2022.116814
24. Saad A, Benyamina AEH, Gamatie A. Water Management in Agriculture: A Survey on Current Challenges and Technological Solutions. IEEE Access. 2020;8:38082–97. https://doi.org/10.1109/ACCESS.2020.2974977
25. Musz-Pomorska A, Widomski MK, Gołębiowska J. Financial Sustainability of Selected Rain Water Harvesting Systems for Single-Family House under Conditions of Eastern Poland. Sustainability. 2020;12:4853. https://doi.org/10.3390/su12124853
26. Musz-Pomorska A, Widomski MK. Analysis of the impact of the degree of catchment sealing on the operation of drainage system. Appl Water Sci. 2022;12:253. https://doi.org/10.1007/s13201–022–01774–5.
27. Semaan M, Day SD, Garvin M, et al. Optimal sizing of rainwater harvesting systems for domestic water usages: A systematic literature review. Resour Conserv Recycl X. 2020;6:100033. https://doi.org/10.1016/j.rcrx.2020.100033
28. Ali S, Sang Y-F. Implementing rainwater harvesting systems as a novel approach for saving water and energy in flat urban areas. Sustain Cities Soc. 2023;89:104304. https://doi.org/10.1016/j.scs.2022.104304
29. Suchorab P, Iwanek M. Efektywność wybranej instalacji dualnej wykorzystującej wody deszczowe w warunkach rzeczywistych opadów. Instal. 2021;435:41–5. https://doi.org/10.36119/15.2021.12.6
30. Behzadian K, Kapelan Z, Mousavi SJ, et al. Can smart rainwater harvesting schemes result in the improved performance of integrated urban water systems? Environ Sci Pollut Res. 2018;25:19271–82. https://doi.org/10.1007/s11356-017-0546-5
31. Judeh T, Shahrour I, Comair F. Smart Rainwater Harvesting for Sustainable Potable Water Supply in Arid and Semi-Arid Areas. Sustainability. 2022;14:9271. https://doi.org/10.3390/su14159271
32. Dao DA, Tran SH, Dang HTT, et al. Assessment of rainwater harvesting and maintenance practice for better drinking water quality in rural areas. J Water Supply Res Technol-Aqua. 2021;70:202–16. https://doi.org/10.2166/aqua.2021.076
33. Florides F, Giannakoudi M, Ioannou G, et al. Water Reuse: A Comprehensive Review Environ. 2024;11:81. https://doi.org/10.3390/environments11040081
34. Sheikh V. Perception of domestic rainwater harvesting by Iranian citizens. Sustain Cities Soc. 2020;60:102278. https://doi.org/10.1016/j.scs.2020.102278
35. Jin Y, Lee S, Kang T, et al. Capacity Optimization of Rainwater Harvesting Systems Based on a Cost–Benefit Analysis: A Financial Support Program Review and Parametric Sensitivity Analysis. Water. 2023;15:186. https://doi.org/10.3390/w15010186
36. Vidal P, Leiva AM, Gómez G, et al. Water Quality of Rainwater Harvesting Systems and Acceptance of Their Reuse in Young Users: An Exploratory Approach. Resources 2024;13:159. https://doi.org/10.3390/resources13110159
37. De Sá Silva ACR, Bimbato AM, Balestieri JAP, et al. Exploring environmental, economic and social aspects of rainwater harvesting systems: A review. Sustain Cities Soc. 2022;76:103475. https://doi.org/10.1016/j.scs.2021.103475
38. Snelling AM, Lamond J, Everett G, et al. Public perceptions of rainwater harvesting (RWH): comparing users and non-users of RWH systems. Urban Water J. 2024;21:181–9. https://doi.org/10.1080/1573062X.2023.2281310
39. Gwenzi W, Dunjana N, Pisa C, et al. Water quality and public health risks associated with roof rainwater harvesting systems for potable supply: Review and perspectives. Sustain Water Qual Ecol. 2015;6:107–18. https://doi.org/10.1016/j.swaqe.2015.01.006
40. Mendez CB, Klenzendorf JB, Afshar BR, et al. The effect of roofing material on the quality of harvested rainwater. Water Res. 2011;45:2049–59. https://doi.org/10.1016/j.watres.2010.12.015
41. Ahmed W, Hamilton KA, Gyawali P, et al. Evidence of Avian and Possum Fecal Contamination in Rainwater Tanks as Determined by Microbial Source Tracking Approaches. Appl Environ Microbiol. 2016;82:4379–86. https://doi.org/10.1128/AEM.00892-16
42. Zhang X, Xia S, Ye Y, et al. Opportunistic pathogens exhibit distinct growth dynamics in rainwater and tap water storage systems. Water Res. 2021;204:117581. https://doi.org/10.1016/j.watres.2021.117581
43. Lay JJ, Vogel JR, Belden JB, et al. Water Quality and the First-Flush Effect in Roof-Based Rainwater Harvesting, Part II: First Flush. Water. 2024;16:1421. https://doi.org/10.3390/w16101421
44. Müller A, Österlund H, Marsalek J, et al. The pollution conveyed by urban runoff: A review of sources. Sci Total Environ. 2020;709:136125. https://doi.org/10.1016/j.scitotenv.2019.136125
45. Hamilton K, Reyneke B, Waso M, et al. A global review of the microbiological quality and potential health risks associated with roof-harvested rainwater tanks. Npj Clean Water. 2019;2:7. https://doi.org/10.1038/s41545-019-0030-5
46. Ahmed W, Vieritz A, Goonetilleke A, et al. Health risk from the use of roof-harvested rainwater in Southeast Queensland, Australia, as potable or nonpotable water, determined using quantitative microbial risk assessment. Appl Environ Microbiol. 2010;76:7382–91. https://doi.org/10.1128/AEM.00944-10
47. Ahmed W, Hodgers L, Sidhu JPS, et al. Fecal indicators and zoonotic pathogens in household drinking water taps fed from rainwater tanks in Southeast Queensland, Australia. Appl Environ Microbiol. 2012;78:219–26. https://doi.org/10.1128/AEM.06554-11
48. Denissen JK, Reyneke B, Waso M, et al. Human Pathogenic Bacteria Detected in Rainwater: Risk Assessment and Correlation to Microbial Source Tracking Markers and Traditional Indicators. Front Microbiol. 2021;12:659784. https://doi.org/10.3389/fmicb.2021.659784.
49. Goshu G, Koelmans AA, De Klein JJM. Performance of faecal indicator bacteria, microbial source tracking, and pollution risk map-

ping in tropical water. Environ Pollut. 2021;276:116693. https://doi.org/10.1016/j.envpol.2021.116693
50. Saxena G, Bharagava RN, Kaithwas G, et al. Microbial indicators, pathogens and methods for their monitoring in water environment. J Water Health. 2015;13:319–39. https://doi.org/10.2166/wh.2014.275
51. Richiardi L, Pignata C, Fea E, et al. Are Indicator Microorganisms Predictive of Pathogens in Water? Water. 2023;15:2964. https://doi.org/10.3390/w15162964
52. Bae S, Maestre JP, Kinney KA, et al. An examination of the microbial community and occurrence of potential human pathogens in rainwater harvested from different roofing materials. Water Res. 2019;159:406–13. https://doi.org/10.1016/j.watres.2019.05.029
53. Harwood VJ, Staley C, Badgley BD, et al. Microbial source tracking markers for detection of fecal contamination in environmental waters: relationships between pathogens and human health outcomes. FEMS Microbiol Rev. 2014;38:1–40. https://doi.org/10.1111/1574-6976.12031
54. Waso M, Khan S, Khan W. Microbial source tracking markers associated with domestic rainwater harvesting systems: Correlation to indicator organisms. Environ Res. 2018;161:446–55. https://doi.org/10.1016/j.envres.2017.11.043
55. Li E, Saleem F, Edge TA, et al. Biological Indicators for Fecal Pollution Detection and Source Tracking: A Review. Processes. 2021;9:2058. https://doi.org/10.3390/pr9112058
56. Skiendzielewski K, Burch T, Stokdyk J, et al. Two risk assessments: Evaluating the use of indicator HF183 Bacteroides versus pathogen measurements for modelling recreational illness risks in an urban watershed. Water Res. 2024;259:121852. https://doi.org/10.1016/j.watres.2024.121852
57. Lancaster E, Lee J. Advanced preparedness for drinking water emergency: Ensuring safe microbial quality with rapid microbial source tracking and E. coli methods. Environ Adv. 2023;13:100426. https://doi.org/10.1016/j.envadv.2023.100426
58. The Human Microbiome Project Consortium. Structure, function and diversity of the healthy human microbiome. Nature. 2012;486:207–14. https://doi.org/10.1038/nature11234
59. Craun GF, Berger PS, Calderon RL. Coliform bacteria and waterborne disease outbreaks. J AWWA. 1997;89:96–104. https://doi.org/10.1002/j.1551–8833.1997.tb08197.x
60. Holcomb DA, Stewart JR. Microbial Indicators of Fecal Pollution: Recent Progress and Challenges in Assessing Water Quality. Curr Environ Health Rep. 2020;7:311–24. https://doi.org/10.1007/s40572-020-00278-1
61. Denamur E, Clermont O, Bonacorsi S, et al. The population genetics of pathogenic Escherichia coli. Nat Rev Microbiol. 2021;19:37–54. https://doi.org/10.1038/s41579-020-0416-x
62. Wilson AM, Martin SL, Verhougstraete MP, et al. Detangling Seasonal Relationships of Fecal Contamination Sources and Correlates with Indicators in Michigan Watersheds. Microbiol Spectr. 2022;10:e00415–22. https://doi.org/10.1128/spectrum.00415-22
63. Dubin K, Pamer EG. Enterococci and Their Interactions with the Intestinal Microbiome. Microbiol Spectr 2017;5:5.6.01. https://doi.org/10.1128/microbiolspec.BAD-0014-2016
64. World Health Organization, editor. Guidelines for drinking-water quality. Fourth edition incorporating the first addendum. Geneva: World Health Organization; 2017.
65. Ko HY, Cho K, Park S, et al. Host-Specific Bacteroides Markers-Based Microbial Source Tracking in Aquaculture Areas. Microbes Environ. 2018;33:151–61. https://doi.org/10.1264/jsme2.ME17166
66. Wang G, Paredes-Sabja D, Sarker MR, et al. Effects of wet heat treatment on the germination of individual spores of Clostridium perfringens. J Appl Microbiol. 2012;113:824–36. https://doi.org/10.1111/j.1365–2672.2012.05387.x
67. Teixeira P, Dias D, Costa S, et al. Bacteroides spp. and traditional fecal indicator bacteria in water quality assessment – An integrated approach for hydric resources management in urban centers. J Environ Manage. 2020;271:110989. https://doi.org/10.1016/j.jenvman.2020.110989
68. hmed W, Hughes B, Harwood V. Current Status of Marker Genes of Bacteroides and Related Taxa for Identifying Sewage Pollution in Environmental Waters. Water. 2016;8:231. https://doi.org/10.3390/w8060231
69. Ahmed W, Gyawali P, Feng S, et al. Host Specificity and Sensitivity of Established and Novel Sewage-Associated Marker Genes in Human and Nonhuman Fecal Samples. Appl Environ Microbiol. 2019;85:e00641–19. https://doi.org/10.1128/AEM.00641-19
70. Wong K, Fong T-T, Bibby K, et al. Application of enteric viruses for fecal pollution source tracking in environmental waters. Environ Int. 2012;45:151–64. https://doi.org/10.1016/j.envint.2012.02.009
71. Kirs M, Moravcik P, Gyawali P, et al. Rainwater harvesting in American Samoa: current practices and indicative health risks. Environ Sci Pollut Res. 2017;24:12384–92. https://doi.org/10.1007/s11356-017-8858-z
72. Chapman HF, Cartwright T, Huston R, et al. Water Quality and Health Risks from Urban Rainwater Tanks. Cooperative Research Centre for Water Quality and Treatment; 2008.
73. Zdeb M, Zamorska J, Papciak D, et al. Investigation of Microbiological Quality Changes of Roof-Harvested Rainwater Stored in the Tanks. Resources. 2021;10:103. https://doi.org/10.3390/resources10100103
74. Bobková Š, Baudišová D, Kožíšek F, et al. Quality of rainwater and reclaimed water used in buildings and selection of appropriate indicators. Cent Eur J Public Health. 2023;31:155–65. https://doi.org/10.21101/cejph.a7884
75. Moses A, Ramírez-Andreotta MD, McLain JET, et al. Assessing the impact of rainwater harvesting infrastructure and gardening trends on microbial indicator organism presence in harvested rainwater and garden soils. J Appl Microbiol. 2023;134:lxad110. https://doi.org/10.1093/jambio/lxad110
76. Chubaka CE, Whiley H, Edwards JW, et al. A Review of Roof Harvested Rainwater in Australia. J Environ Public Health 2018;2018:1–14. https://doi.org/10.1155/2018/6471324
77. Kaushik R, Balasubramanian R, Dunstan H. Microbial Quality and Phylogenetic Diversity of Fresh Rainwater and Tropical Freshwater Reservoir. PLoS ONE. 2014;9:e100737. https://doi.org/10.1371/journal.pone.0100737
78. Staley C, Gordon KV, Schoen ME, et al. Performance of Two Quantitative PCR Methods for Microbial Source Tracking of Human Sewage and Implications for Microbial Risk Assessment in Recreational Waters. Appl Environ Microbiol. 2012;78:7317–26. https://doi.org/10.1128/AEM.01430-12
79. Anindita M, Rahman A, Alim MA, et al. Microbial ecology of harvested rainwater: Assessing quality, antimicrobial resistance and geographical variation. J Clean Prod. 2025;486:144439. https://doi.org/10.1016/j.jclepro.2024.144439
80. Szeląg B, Barros V, Kiczko A, et al. A quantitative microbial risk assessment (QMRA) framework for optimizing harvestable volume in stormwater reuse systems. Ecol Eng. 2026;227:107964. https://doi.org/10.1016/j.ecoleng.2026.107964
81. Owens CEL, Angles ML, Cox PT, et al. Implementation of quantitative microbial risk assessment (QMRA) for public drinking water supplies: Systematic review. Water Res. 2020;174:115614. https://doi.org/10.1016/j.watres.2020.115614
82. Szelag B, De Simoni L, Kiczko A, et al. Towards stormwater reuse risk management plans: Methodology and catchment scale evaluation of QMRA. Sci Total Environ. 2025;964:178552. https://doi.org/10.1016/j.scitotenv.2025.178552
83. Zhang Q, Gallard J, Wu B, et al. Synergy between quantitative microbial source tracking (qMST) and quantitative microbial risk assessment (QMRA): A review and prospectus. Environ Int. 2019;130:104703. https://doi.org/10.1016/j.envint.2019.03.051
84. Heyworth J, Glonek G, Maynard E, et al. Consumption of untreated tank rainwater and gastroenteritis among young children in South Australia. Int J Epidemiol. 2006;35:1051–8. https://doi.org/10.1093/ije/dyl105
85. Dean JME, Deare F, Kydd K, et al. Rainwater harvesting in rural Trinidad; a cross sectional, observational study. J Water Sanit Hyg Dev. 2012;2:241–9. https://doi.org/10.2166/washdev.2012.102
86. Pham-Duc P, Nguyen-Viet H, Hattendorf J, et al. Diarrhoeal diseases among adult population in an agricultural community Hanam province, Vietnam, with high wastewater and excreta re-use. BMC Public Health. 2014;14:978. https://doi.org/10.1186/1471-2458-14-978
87. Hora JD, Cohim EB, Sipert S, et al. Quantitative Microbial Risk Assessment (QMRA) of Campylobacter for Roof-Harvested Rainwater Domestic Use. 2nd Int. Electron. Conf. Water Sci., MDPI; 2017. p. 185. https://doi.org/10.3390/ecws-2-04954
88. Lim K-Y, Jiang SC. Reevaluation of health risk benchmark for sustainable water practice through risk analysis of rooftop-harvested rainwater. Water Res. 2013;47:7273–86. https://doi.org/10.1016/j.watres.2013.09.059
89. Schoen ME, Xue X, Hawkins TR, et al. Comparative Human Health Risk Analysis of Coastal Community Water and Waste Service Options. Environ Sci Technol. 2014;48:9728–36. https://doi.org/10.1021/es501262p
90. Fewtrell L, Kay D. Quantitative microbial risk assessment with respect to Campylobacter spp. in toilets flushed with harvested rainwater. Water Environ J. 2007;21:275–80. https://doi.org/10.1111/j.1747-6593.2007.00088.x